



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4640BO7028

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Distributor <i>Vertreiber</i>	Aalberts integrated piping systems B.V. Oude Amersfoortseweg 99, NL-1212 AA Hilversum
Product Category <i>Produktart</i>	Gas installation components : Safety gas connection valve (4606)
Product description <i>Produktbezeichnung</i>	safety gas hose connection optionally with thermally activated shutt-off device
Model <i>Modell</i>	5553
Test reports <i>Prüfberichte</i>	Laboratory control test: 22-00353-KP01-312 from 25.07.2022 (EBI) Type testing: 10/082/4604/106 from 04.02.2011 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 15069 (01.07.2010)

Date of Expiry / File No. 27.06.2025 / 24-0482-GNU
Ablaufdatum / Aktenzeichen

20.09.2024 Bd B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

G. Schmidt



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
5553	Typ Nominal diameter: DN 15 Ambient temperature range: -40...+60 °C Max. operating pressure: 500 mbar	Technische Daten Bemerkungen
Hints of Utilization / Remarks		
Verwendungshinweise / Bemerkungen		
connection on the outlet side: external thread R 1/2 according to DIN EN 10226-1		

